

جراي ماكنزي للخدمات الهندسية (ش.ذ.م.م.)

Gray Mackenzie Engineering Services L.L.C.

United Arab Emirates Tel: 00 971 4 3241380 Fax: 00 971 4 3241384 E-Mail: mail@gmes.ae

CERTIFICATE OF CONFORMANCE

ISSUED BY THE TESTING LABORATORY OF GRAY MACKENZIE ENGINEERING SERVICES L.L.C.

Document No

Job No.

Client Reference

Lab Reference

Certificate No.

: 38528

Date of Issue

: 24-Aug-14

Gray Mackenzie Engineering Services L.L.C.

P.O. Box 32393, Shed 118 Al Jadaf, Dubai UAE

Tel. No. : 4 324 1380 : 4 324 1384

Client Name

www.gmes.ae

Testing Procedure

: Intertek

Appliance Description : Tube Light Fitting : TLX-PCPC 2X36WHF, IP65 Model / Type

: Thornlux Manufacturer

Appliance Serial No. Testing Date

: 004550350090814 : 24-Aug-14 : IEC-60598-1

Approved by Signature *

Name:

A. Vijayasundaram

: CVG-230, CAT-II-30, 02 Dec 2013 : 1104191

: JULGM43 : 20516 : 7527

17025 Data Sheet No. Laboratory Temp/Humidity : 22 ± 3°C

Sr. No.	Standard Clause No.	Brief Test Description	Measured Value	Remarks/UC
1	3.2	MARKING:		
		Marking shall be distinct and durable:	Yes	
		Height of Graphical Symbol:	N/A	
		Rated Wattage:	2x36W	
		Shape of Cool Beam Lamps:	N/A	
		Symbol for Bowl Mirror Lamp:	N/A	
		Marking of "Replace Any Cracked Protective Shield":	N/A	PASSED
		Manufacturer's Name:	Thornlux	
		Rated Voltage:	220/240V	
		(Where Applicable) Symbol for Class II:	N/A	
		(Where Applicable) Symbol for Class III:	N/A	
		Model No:	TLX-PCPC2X36WHFIP65	
		Termination shall be clearly marked:	Yes	
2	7.2.1	PROVISION FOR EARTHING:		
		Earth Bonding Resistance.	N/A	Not Applicable
3	9.3	HUMIDITY TEST:		
		Test has been carried out at 91% to 95% at temperature 25°C.	No Failure	PASSED
4	10.2	INSULATION RESISTANCE & ELECTRIC STRENGTH:	مات المهن	ان ي للفد
		Insulation Resistance:	>299710	13
		Electric Strength:	No Breakdown	PASSED
-	10.3	LEAN ACE CURRENT TOUCH CURRENT	11.3.4	الم السي
5	10.3	LEAKAGE CURRENT/TOUCH CURRENT:	0.0184 P.O.Bo	32393
		Touch current has been measured.	II N Dubai	MAT. TOTAL
6	12.4	THERMAL TEST: (normal use)	2.6°C Enc	/ cor
		Body:	2.6°C Tenzio E	Phipon
		Lamp Holder:	5.1°C	MEPASSED
		70000 A		
1.5			1	

GMES/LAB/FRM-09, REV 2, Jun 2012

Page 1 of 2



جر اي ماكنزي للخدمات الهندسية (ش.ذ.م.م.) Gray Mackenzie Engineering Services L.L.C.

صب: ٣٢٩٦٣. يبي الإمارات العربية المتحدة نتيفون: ١٩٧١ - ٢٢٤١٣٨٠ - التيفون: ١٩٧١ - ٢٣٤١٣٨٠ - الكتاب المتالكة عند المتالكة (P.O. Box: 32393 Dubai United Arab Emirates Tel: 00 971 4 3241380

Tel: 00 971 4 3241380 Fax: 00 971 4 3241384 E-Mail: mail@gmes.ae

CERTIFICATE OF CONFORMANCE

ISSUED BY THE TESTING LABORATORY OF GRAY MACKENZIE ENGINEERING SERVICES L.L.C.

Certificate No.

: 38528

Date of Issue

: 24-Aug-14

Sr. No.	Standard Clause No.	Brief Test Description	Measured Value	Remarks/UC
7	13.2.1	RESISTANCE TO HEAT: Ball Pressure Apparatus has been placed with temperature of 125°C of current carrying parts and 75°C of other parts.	No Failure	PASSED
8	SASO	ESSENTIAL REQUIREMENTS: Rated Voltage: Rated Frequency: Plug: Country of Origin: Instruction Manual:	220/240V 50/60H= N/A UAE N/A	PASSED

The reported Expanded Uncertainty of measurement is \pm As above with a coverage factor K = 2, assuming a normal distribution at a level of confidence of 95%. The standard uncertainty of measurement has been determined in accordance with ISO 17025 Requirements.

Comment(s)

• The quoted Uncertainty refers only to the measured value and does not carry any implication regarding the long term stability of the Appliance.

Testing Reference Standard:

The Appliance has been Tested against:

- 1. PAT, Model No: 6500, Serial No: RO1273028
- 2. Insulation Tester, Model No: 3455, Serial No: 100310385

Analyst

Signature Name

m)

Waqar Ahmad

P.O. BOX 32393
Dubai - U.A.E.

Box Bridge Engineering Service Figure 1986

End of Certificate

Note 1. The Clients are requested to collect their samples within 30 days of issuance of test certificates. Due to limited storage space, GMES can not store the samples for long time and reserves the rights to dispose off the samples. GMES will not entertain any sample claim after 30 days from issuance of test certificates.

Note 2. This certificate is issued in accordance with the requirements of ISO 17025. It provides traceability of measurements to recognised national / international Standards and to units of measurements realized to recognized national / international standard laboratories. This certificate may not be reproduced, except in full, without prior written approval of the laboratory.

GMES/LAB/FRM-09, REV 2, Jun 2012

Page 2 of 2